

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7167-0495:118 Page 1 of 1

**CATEGORY:** Control Units (Household)

**LISTEE:** Fire Burglary Instruments, 165 Eileen Way, Syosset NY 11791  
Contact: Dave Kalmus (516) 921-6704 Ext 1910 Fax (516) 364-6953

**DESIGN:** Model XL-2T combination household fire and burglary warning system control unit with integral digital alarm communicator. Also suitable for use with other separately listed accessories and devices as indicated in the manufacturer's installation and operating instructions. Each control unit is compatible with models XK-406, XL-4600RM, XL-4600SM, 6615, XK-508, XK-5LC, XK-7LC keypads. Refer to listee's data sheet for detailed product description and operational considerations.

**OPTIONS:** Refer to listee's data sheet for required/optional accessories. When required, accessories shall be CSFM listed.

**RATING:** 120 VAC, 12 VAC Secondary, 12 VDC Standby

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as household combination fire and burglary alarm control unit for use with separately listed compatible initiating and indicating devices.

This control unit can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72 1999 Edition. Refer to manufacturer's Installation Manual for details.

**NOTE:**

1. Fire Alarm Verification Feature (delay of fire alarm) shall NOT be used in California.
2. Burglary and other non-fire functions were not examined.
- 3.

11-08-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JULY 3, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager